



CITY OF PALO ALTO

PURCHASING AND CONTRACT ADMINISTRATION

250 HAMILTON AVENUE
PALO ALTO, CA 94301

P.O. BOX 10250
PALO ALTO, CA 94303

Date: October 15, 2009

Subject: Addendum Number One to City of Palo Alto Request for Proposal (RFP) Number 133424

Project Title: Redesigning and Rebuilding of Gas Receiving Stations

Department: Utilities, Engineering Division

Bid Opening Date: 3:00 p.m., Tuesday, November 3, 2009

Please note the following changes, corrections, and clarifications that are hereby incorporated to the requirements of the RFP:

Question:

Do any of the existing facilities at stations 1,2 or 3 to be demolished by the City of Palo Alto have filters now? If so what are they designed to filter from the system? (type and quantity of contaminant)

Do you have the make and model number of these filters - if they are currently installed?

Is the City of Palo Alto experiencing any problems due to contaminants in the gas? If so what are the contaminants? If you are having operational problems due to contaminants what are the problems you are seeing? Does the City of Palo Alto have standards for the quality of gas supplied to the City's customers that are more stringent than the standards PG and E has for the gas PG and E supplies to the City of Palo Alto?

Answer: Our existing gas facilities do not have upstream filters, as we do not experience problems associated with liquids and other contaminants. Upstream filters listed in the design requirements were intended for filtering dry dust that may occur in the pipelines. However, we are looking for recommendation from the proposing firms whether or not filters are required and suggestion on filter manufacturer.

The Proposal Opening Date of 3:00 P.M. Tuesday, Nov. 3, 2009 remains unchanged.

Carolynn Bissett
Contract Administrator
City of Palo Alto

Cc: Aleksandr Pishchik, Project Manager