



CITY OF PALO ALTO

PURCHASING AND CONTRACT ADMINISTRATION

250 HAMILTON AVENUE
PALO ALTO, CA 94301

P.O. BOX 10250
PALO ALTO, CA 94303

Date: October 27, 2009

Subject: Addendum Number Two to City of Palo Alto Request for Proposal (RFP) Number 133424

Project Title: Redesigning and Rebuilding of Gas Receiving Stations

Department: Utilities, Engineering Division

Bid Opening Date: 3:00 p.m., Tuesday, November 10, 2009**New Date******

Please note the following changes, corrections, and clarifications that are hereby incorporated to the requirements of the RFP:

1. The design parameters for Gas Receiving Stations are based on information provided by PG&E for gas flow. Please change in Scope of Work under Design, Parameters for Gas Receiving Stations (Page 1 of 4)

From: The flow to the Stations is approximately:

Station 1: PG&E meter sized for delivery of 1,035,000 SCFH @ 60 psig
Station 2: PG&E meter sized for delivery of 666,600 SCFH @ 55 psig
Station 3: PG&E meter sized for delivery of 385,570 SCFH @ 60 psig
To VA Hospital 90, SCFH

To: The flow to the Stations is approximately:

Station 1: PG&E flow to the station 970,000 SCFH @ 60 psig
Station 2: PG&E flow to the station 970,000 SCFH @ 60 psig
Station 3: PG&E total flow to the station 475,570 SCFH @ 60 psig (includes 90,000 SCFH to VA Hospital).

Add to Design Requirements for Gas Receiving Stations (Page 2 of 4):

Each run must handle entire station flow

- Answers to questions submitted will be answered on or before Oct. 29, 2009.
- The Proposal Opening Date is changed from 3:00 p.m. Tuesday, Nov. 3, 2009 to 3:00 p.m. Tuesday, Nov. 10, 2009.

Carolynn Bissett / Contract Administrator