



DEVELOPEMENT REVIEW CHECKLIST/COMMENTS

Fire Apparatus Access Plan

- This plan shall be single layer and include all access routes and their dimensions.
- Show turning radius' meet PAFD Apparatus Specs.
- Show Ladder Truck placement with ladder extension to all roofs if applicable.
- Show Ladder Truck elevation with ladder extension to all roofs if applicable. Show
- usable Fire Hydrants (Public and Private), Hydrant Spacing, Hydrant type. Show
- Backflow protection.
- Show OS&Y location(s).
- Show FDC location(s). (May require a new Fire Hydrant with 25' of new FDC on same side of street)
- Show PIV location(s).
- Show Fire Fighter Path of Travel all accessible areas.
- Show Painted Curbs in areas designated as no parking for fire access.
- Provide a turnaround meeting the Apparatus Specs at the dead end of the access way. (if applicable)
- Show Knox Box locations. Call PAFD Prevention Bureau at 650-329-2184 for details and order form. All
- Fire Access Requirements shall be inspected prior to building final and Certificate of Occupancy.

John Parks

Senior Fire Inspector/Arson Investigator/Project Manager

john.parks@cityofpaloalto.org

650.329.2589