

NOTES:


1. Surface of steel plates shall be roughened, taped, or coated to provide a non-skid surface for safety of the traveling public.
2. Steel plates shall be removed within 14 calendar days after placement.
The Contractor may apply to Public Works Engineering Division for an extension to these deadlines. A penalty may be assessed for each day these deadlines are not met.
3. A maximum of 300 feet or one City block of trench, whichever is greater, may be opened at one time.
4. All cutback shall be placed so there will be a 12:1 slope, or up to 18:1 where required by Public Works Inspector to provide a smooth transition.
5. Notify Public Works Inspector at 650-496-6929 whenever a trench plate is installed or removed.
6. Contractor shall adjust and conform plate for a smooth riding surface as necessary for the duration of the Work.
7. Trench plate may be required to be pinned down, depending on field condition and as directed by Public Works Inspector.

Rev	By	Date
0	JT	07/24/06
1	HQN	10/17/06
2	RTN	08/11/17

Scale: NTS

Trench Plates

City of Palo Alto Standard

Approved by:	
PE No.	72158
Date	01/10/18
Dwg No.	404